

Annexure C


PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. MEMO

Dated: 23/05/2026

It is certified that an inspection team headed by LALIT KUMAR, CLERK
(Name of Officers with designation) from N.P.P. GAJRAULA DIST. AMROHA PHED
inspected the OXFORD INTERNATIONAL SCHOOL, NH-24, OPP. U.S. FOODS, GAJRAULA
(Name & Address of the school) on 23/05/2026 (date of inspection) and on the basis of
Water Test Report (Attached) bearing no. 2351/प्रमो गजरावा अमरोहा 14 dated 21/05/2026
of DISTRICT LEVEL WATER ANALYSIS LABORATORY U.P. JAL NIGAM AMROHA PHED Lab
certified that the OXFORD INTERNATIONAL SCHOOL (Name of school)
has safe drinking water facilities for the students and members of staff of the institution.
School is also maintains the hygienic sanitation condition in the school building & the
campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till One year from the issued date.

Signature with Seal: 
अधिसूचना अधिकारी
नगर पालिका परिसर
गजरावा (अमरोहा)

Name : LALIT KUMAR ARYA

Designation : EXECUTIVE OFFICER

Name & Address of the Office / Department :

N.P.P. GAJRAULA DIST.

AMROHA

To

Oxford International School

NH-24, Opposite US FOODS

Gajraula, Dist. Amroha

(Name & Address of the Institution)



कार्यालय

अधिशाली अभियन्ता, खण्ड कार्यालय, उ०प्र० जल निगम (ग्रामीण),
इमली वाली मढैयां, हुसैनपुर चौराहा/आर०टी०ओ० बाईपास, निकट कन्हैया टायर हाउस,
अमरोहा-244221

पत्रांक 235 / प्रयोगशाला अमरोहा / 41 दिनांक 21-05-26

सेवा में,


Principal,
Oxford International School,
Gajraula, (Amroha) 244235

विषय- पानी की जांच के संबंध में।

महोदय,

उपरोक्त विषयक आपके पत्रांक OIS/OFL/238 दिनांक 14.05.2026 के संदर्भ में खण्डीय प्रयोगशाला अमरोहा में कार्यरत श्री ललित कुमार (सैम्पल अस्टिंट) द्वारा दिनांक 15.05.2026 को Oxford International School, Gajraula, Distt. Amroha में उपस्थित होकर लाये गये पेयजल नमूने की जांच खण्डीय प्रयोगशाला में की गयी। जांचोपरान्त जांच रिपोर्ट संलग्न कर प्रेषित है।
संलग्नक:- उपरोक्तानुसार।


भवदीय


(चन्द्रहास)

अधिशाली अभियन्ता

पृ०सं० एवं दिनांक उपरोक्तानुसार।

प्रतिलिपि:- सहायक अभियन्ता/जू०इंजी० लैब को सूचनार्थ हेतु प्रेषित।


अधिशाली अभियन्ता



(NABL Accredited)
DISTRICT LEVEL WATER ANALYSIS
LABORATORY
U.P. JAL NIGAM (RURAL), AMROHA
KHAND KARYALAY, ATRASI TO JOYA BYPASS ROAD, AMROHA, UTTAR PRADESH,
INDIA 244221

Report No. 26/05/31/11 Date: 19.05.26 Lab Id: Page No. 12

Customer Details

Office Name and Address **OXFORD INTERNATIONAL SCHOOL GAJRAULA Distt. Amtoha**
Ref Letter No & date OIS/OFL/238 Dated: 14.05.26

Basic details of sample

District	Amroha	Block	Gajraula
Gram Panchayat	-	Village	-
Habitation	-	Location	Oxford International School Gajraula
Water Source Type	RO Plant	Sample No.	AMR/C/26/31
Quantity of Sample	1000 ML	Date of S.C	15/05/2026
S. Receiving Date	15/05/2026	Sample Provide by	Mr.Lalit Kumar
Sample Submit	15/05/2026	Sampling Method Used	IS 17614 (Part 1):2024
Analysis Done By	Chemist/Lab Assistant		
Analysis Start Date : 18/05/2026	Analysis Completion date : 18/05/2026	Result Availability Date : 18/05/2026	

Environmental Condition

Temperature 25±3°C Relative Humidity Up to 50±15

Technical Data of Analysis

S.N	Analysed Parameters (Unit of Measurement)	Observed Value	Specified Values as per IS 10500:2012		Ref Method of Analysis
			Acceptable Limit	Permissible Limit	
1	2	3	4	5	6
1	Colour (HU)	05	5	15	IS 3025 P-4:2021
2	pH	8.068	6.5-8.5	6.5-8.5	IS 3025 P-11:2022
3	TURBIDITY (NTU)	3.43	1.0	5.0	IS 3025 P-10:2023
4	TDS (mg/l)	186.0	500	2000	IS 3025 P-16:2023
5	CHLORIDE (mg/l)	240.00	250	1000	IS 3025 P-32:2019
6	TOTAL ALKALINITY(mg/l)	40.00	200	600	IS 3025 P-23:2023
7	TOTAL HARDNESS(mg/l)	180.00	200	600	IS 3025 P-21:2019
8	As Calcium (mg/l)	27.23	75	200	IS 3025 P-40:2019
9	As Magnesium (mg/l)	27.30	30	100	IS 3025 P-46:2019
10	Fluoride (mg/l)	0.04	1.0	1.5	Apha23th edition-4500 F- Method C (Electrode method):2023

Note —This Certificate refers only to the particular sample(s) submitted for testing..

1. This Certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.
2. The test results reported in this certificate are valid at the time of send under the stated conditions of measurements.
3. Sample will be stored up to 7 days. (in case of non-perishable items only) from the date of issue of tests report unless.


CHEMIST
Water Testing Laboratory
U.P. Jal Nigam, Amroha

.....End Of The Report.....



BACTERIOLOGICAL ANALYSIS REPORT
DISTRICT LEVEL WATER ANALYSIS LABORATORY

U.P, JAL NIGAM (RURAL) AMROHA

Address- Khand karyalay, Atrasi to Joya bypass Road Amroha Uttar Pradesh Pin-244221

Report No. 26/05/31/11	Date	19.05.26	Page No.	12
------------------------	------	----------	----------	----

Customer Details

Office Name and Address	OXFORD INTERNATIONAL SCHOOL GAJRAULA Distt. Amtoha
-------------------------	--

Ref Letter No & date	OIS/OFL/238 Dated: 14.05.26
----------------------	-----------------------------

Basic details of sample

District	Amroha	Block	Gajraula
Gram Panchayat	-	Village	-
Habitation	-	Location	Oxford International School Gajraula
Water Source	Ro Plant	Sample No.	AMR/B/26/31
Quantity of Sample	1000 ML	Date of S.C	15/05/2026
Receiving Date	15/05/2026	Sample Provide by	Mr. Lalit Kumar
Sample Submit	15/05/2026	Sampling Method Used	IS 17614 (Part 1):2024
Analysis	Microbiologist		
Analysis Start Date	15/05/2026	Analysis Completion date-	15/05/2026
		Result Availability Date-	19/05/2026

Environmental Condition

Temperature	25±3°C	Relative Humidity	Up to 50±15
-------------	--------	-------------------	-------------

Technical Data of Analysis

S.N	Analysed Parameters (Unit of Measurement)	Unit	Observed Value	Specified Values as per IS 10500:2012		Ref Method of Analysis
				Acceptable Limit	Permissible Limit	
1	2	3	4	5	6	7
1	E.COLI	CFU	00	Shall not be detectable in 100 ml Sample		APHA 23 rd Edition : 2017
2	T.COLI	CFU	00	Shall not be detectable in 100 ml Sample		APHA 23 rd Edition : 2017

Note —This Certificate refers only to the particular sample(s) submitted for testing..

1. This Certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.
2. The test results reported in this certificate are valid at the time of send under the stated conditions of measurements.
3. Sample will be stored up to 7 days. (in case of non-perishable items only) from the date of issue of test report unless.

(Microbiologist)
Authorized Signatory

.....End Of The Report.....